

eco-design-regulation EU 2016/2281

Requirements for the documentations (appendix 2 / chapter 5 / table 15)

Unit omega.k/t 270 L			.k/t 270 L -eco-
Type of liquefaction	L (air cooled		
Refrigerant/GWP			R410a/2088
	Symbol	Value	Unit
Operating temperature	t	7	°C
Seasonal energy performance ratio	SEPR	5.36	
Annual energy consumption	Q	25,799	kWh/a
Reduction factor C_{dc} of chillers	C_{dc}		
Power regulation		variabel	
Parameter at full load and reference tempero	ature at assessment point A		
Rated refrigeration capacity	P _A	18.66	kW
Rated power consumption	D _A	7.17	kW
Power regulation	EER _{DC,A}	2.60	
Parameter at assessment B			
Declared cooling capacity	P_{B}	17.42	kW
Declared power consumption	$D_{_B}$	4.79	kW
Declared energy efficiency ration	EER _{DC,B}	3.63	
Parameter at assessment C			
Parameter at assessment C Declared cooling capacity	P _c	16.17	kW
		16.17 3.16	
Declared cooling capacity	P _c D _c EER _{DC,C}		
Declared cooling capacity Declared power consumption	D_c	3.16	
Declared cooling capacity Declared power consumption Declared energy efficiency ration	D_c	3.16	kW
Declared cooling capacity Declared power consumption Declared energy efficiency ration Parameter at assessment D	D _c EER _{DC,C}	3.16 5.12	kW kW kW kW