

eco-design-regulation EU 2016/2281

Requirements for the documentations (appendix 2 / chapter 5 / table 15)

Unit omega.k/t 600 L -			
Type of liquefaction	L (air cooled)		
Refrigerant/GWP			R410a/2088
	Symbol	Value	Unit
Operating temperature	t	7	°C
Seasonal energy performance ratio	SEPR	5.75	
Annual energy consumption	Q	57,297	kWh/a
Reduction factor C_{dc} of chillers	C_{dc}		
Power regulation		variabel	
Parameter at full load and reference tempera	ature at assessment point A		
Rated refrigeration capacity	P _A	44.46	kW
Rated power consumption	D _A	17.53	kW
Power regulation	EER _{DC,A}	2.54	
Parameter at assessment B			
Declared cooling capacity	P _B	41.50	kW
Declared power consumption	$D_{_B}$	10.95	kW
	- B		N V V
Declared energy efficiency ration	EER _{DC,B}	3.79	
Declared energy efficiency ration Parameter at assessment C			
Parameter at assessment C	P _C	3.79	kW
Parameter at assessment C Declared cooling capacity	EER _{DC,B}	38.54	kW
Parameter at assessment C Declared cooling capacity Declared power consumption	P _C D _C	3.79 38.54 7.30	kW
Parameter at assessment C Declared cooling capacity Declared power consumption Declared energy efficiency ration	P _C D _C	3.79 38.54 7.30	kW kW
Parameter at assessment C Declared cooling capacity Declared power consumption Declared energy efficiency ration Parameter at assessment D	P _C D _C EER _{DC,C}	3.79 38.54 7.30 5.28	kW kW